

PETROBRAZI COGENERATION PLANT (ROMANIA) POSTCOMBUSTION WITH HEAVY OIL & NATURAL GAS

JC. Gauthier (Head of Rn'D Dept / PILLARD EGCI, Marseille - France)

In 2001, HYUNDAI Engineering & Construction Co. Ltd of Korea (HDEC), realized for SNP Petrom SA, Romania, a 50 MWe cogeneration plant comprising 2 identical lines on the PETROBRAZI refinery site (60 km north of BUCHAREST). 4 PILLARD type GRC INDUCT burner heads, firing heavy fuel oil in postcombustion on each line, have been supplied and installed upstream to the HRSG.




Fig. 1 : View of the HRSG equipped with the PILLARD burner system

Main characteristics :

- | | |
|-------------|---|
| Gas turbine | : Nuovo Pignone MS-5001 - 2 x 26,57 MWe |
| HSRG | : Hyundai 2 x 134,8 t/hr steam 37,5 bar/340°C (TEG + postcombustion) |
| TEG | : Max. flow : 125 kg/s at 487°C |
| | : O ₂ % : 15,5 % O ₂ (sec, vol) |
| | : Water content : 7,8 % / 11,1 % (with/without steam injection or DeNOx in the gas turbine) |
| Burners | : 4 PILLARD GRC INDUCT burner heads, 50 MW at nominal load, 60 MW maxi (no operation with ambient air) |
| | Fuels : heavy fuel oil, 5 tons/hr per burner, or natural gas, 3 800 kg/hr per burner |

EMISSION TARGETS

For this plant, the main fuel is heavy fuel oil, natural gas being in stand-by. The emissions guaranteed are those measured at stack including those of the Gas Turbine (Fig.2).




Fig. 2 : Contractually guaranteed emissions of NO_x & CO

The limits for emissions generated by the burners are therefore :

$$\text{CO} \leq 97 \text{ mg/MJ}$$

$$\text{NO}_x \leq 260 \text{ mg/MJ}$$

CHOSEN COMBUSTION TECHNIQUE

4 PILLARD GRC INDUCT burner heads, dual-fuel fired (PILLARD patent 97/02586) are located in the duct (Fig. 3). Each head can be dismantled for maintenance thanks to a (rail + door) system.

Such a burner type allows :

- a high flame stability
- low NO_x, CO and dust emissions
- a low pressure drop (10 to 30 mmWG)

The heavy fuel oil is atomized by steam (11 bar, 270°C, flow rate :10 % of the fuel flow). Each burner oil gun can be withdrawn from the side of the duct even in operation (Fig. 4).

When withdrawing the oil gun, the burner head may continue to operate in gas firing mode.




Fig. 3 : Location of the burner heads in the duct




Fig. 4 : Principle of oil gun dismantling



Fig. 5 : External view of a dismantling door



Fig. 6 : Heavy fuel oil flame

STUDY OF COMBUSTIVE FLOWS

A modelization by FLUENT® software (property of FLUENT Inc.) has been utilized to achieve a good TEG distribution across the burner in spite of a limited pressure drop (incl. burner) for a total of 58 mmWG.

Such a study resulted in the addition of 2 perforated plates and a slight modification to the upper part of the duct




Fig. 7 : Flow before treatment and mod of duct




Fig. 8 : Flow after addition of plates

At an average velocity of 28 m/s, the initial dispersion (0 to 60 m/s) becomes (22 to 32 m/s), i.e. -20 /+15 %.

During the burner commissioning, the very homogeneous flame shapes confirmed good combustive distribution.

REAL PERFORMANCES AS MEASURED

The acceptance tests were carried out in April 2003. The 2 lines were in operation (TEG + postcombustion) at the nominal steam production.

The steam injection system of GT (aiming at reducing their NOx emissions) was operating (2.2 to 2.6 kg/s water injection).

| PETROBRAZI site Combustion data in TEG+PC mode | | | |
|--|-----------------------|---|--|
| Type of fuel : Heavy fuel oil | | | |
| | | Measured values | |
| | | Contractual guarantees | 1 |
| | | April 13, 03 (water injection in GT = 2,39-2,50 kg/s) | April 12, 03 (water injection in GT = 2,21 kg/s) |
| Line number | | N° 1 | N° 2 |
| GT power | (MW) | 31 | 27,3 |
| GT load | (%) | 100 | 88 |
| Temperature upstream burner (high/med/low level) | (°C) | 487 | 502/502/500 |
| Postcombustion load | (%) | 100 | 98 |
| Steam flow | (t/h) | 134,9 | 132 |
| Oil pressure heads 1/2/3/4 | (bar) | | 19,5/20,5 |
| Burner kiln temperature | (°C) | | 150 |
| Ato. steam pressure heads1/2/3/4 | (bar) | | 10/11 |
| Total oil flow | (kg/h) | 4 089 | 4 300 |
| Burner heat release | (MW) | 48,27 | 53,83 |
| Temperature at HRSG inlet (high/med/low level) | (°C) | 805,3 | 784/783/841 |
| TEG temperature at HRSG outlet (high/med/low level) | (°C) | 147,2 | 154/152/151 |
| O ₂ upstream burner | (%) | 15,52 | 15,9 |
| O ₂ downstream burner (stack) | (%) | 12,83 | 12,9 |
| CO upstream burner at real O ₂ | (ppm) | | 4 |
| CO upstream burner at 15% O ₂ | (ppm) | 10 | 5 |
| CO upstream burner at 3% O ₂ | (mg/Nm ³) | | 18 |
| CO downstream burner at real O ₂ | (ppm) | | 51 |
| CO downstream burner at 3% O ₂ (stack) | (mg/Nm ³) | 140 | 141 |
| CO downstream burner (stack) | (mg/MJ) | 97 | 97 |
| NOx upstream burner at real O ₂ | (ppm) | | 69 |
| NOx upstream burner at 15 % O ₂ | (ppm) | 65 | 81 |
| NOx upstream burner at 3% O ₂ | (mg/Nm ³) | | 507 |
| NOx downstream burner at real O ₂ (stack) | (ppm) | | 125 |
| NOx downstream burner at 3% O ₂ (stack) | (mg/Nm ³) | 575 | 573 |
| NOx downstream burner (stack) | (mg/MJ) | 257 | 189 |

The NOx and CO emissions are confirmed to be in compliance with guaranteed ones in spite of a nitrogen % in the heavy oil (0.39 %) almost double that which was contractually specified (0.2 %) and in spite of an NOx content upstream to the burner 25 % higher than contractually specified (81 ppm instead of 65 ppm at 15 % O₂)

The very good combustion quality can be verified by the lack of any visible dust at the stack outlet.

CONCLUSION

This plant proves :

- The efficiency of using FLUENT® software to get a better combustive distribution
- The good suitability of the GRC INDUCT technique with heavy oil firing in postcombustion :
 - easy maintenance of oil guns
 - possibility to adjust the flame shapes just by replacing the atomization multinozzles
 - high flame stability
 - low emission of NOx-CO-dust.