

## COMBINED HEAT & POWER PRODUCTION AT TIOXIDE Cy, in Calais (F)

D. NICOLINI (Deputy to the Head of Contracts Dept) (PILLARD (EGCI), Marseilles - France)  
 JC. GAUTHIER (Head of Rn'D dept ) (PILLARD (EGCI), Marseilles - France)

In 2000, TRACTEBEL Energy Engineering realized for the TIOXIDE Cy, Calais (F) a plant including :

- A cogeneration unit of 47 MWe including postcombustion
- Two auxiliary boilers of 38 and 61 MW maintained in "stand by" mode

The plant is managed by ELYO Cy.

### 1 - COGENERATION UNIT

The HRSG supplied by STANDARD FASEL LENTJES (NL) is equipped with a "TEG" by-pass including a vent and diverter and with a PILLARD postcombustion burner REBURNFLAM® type operating in either TEG or ambient air mode.

Main characteristics :

Gas turbine	: LM 6000 GE, 47 MWe
HRSG	: 75 t/hr steam at 71 bar/480°C + 10 t/hr low pressure steam at 20 bar/250°C
TEG	: Max flow : 128,8 kg/sec at 455°C O <sub>2</sub> content : 14,2 % H <sub>2</sub> O content : 6,2 %
PILLARD burner type REBURNFLAM®	: In TEG mode : P = 1,7 to 50 MW (turndown ratio 1 to 30) In ambient air mode : P = 1,7 to 90 MW (turndown ratio 1 to 50) Fuel : Natural gas Number of rows : 6 (operation possible with 2, 4 or 6 rows)

In ambient air mode, the combustion air is supplied by 2 fans located symmetrically each side of the duct, upstream to the burner.




Fig.1 - General outlook of the Cogeneration unit

## EMISSIONS LIMITS AS SPECIFIED

### In TEG mode :

The emissions limits for NO<sub>x</sub> and CO are identical to those at the turbine outlet. Therefore the burner must refrain from increasing them.

#### Turbine emissions :

NO<sub>x</sub> < 50 mg/Nm<sup>3</sup> (@ 15 % O<sub>2</sub> dry)

CO < 80 mg/Nm<sup>3</sup> (@ 15% O<sub>2</sub> dry)

#### Emissions downstream from the burner :

NO<sub>x</sub> < 50 mg/Nm<sup>3</sup> (@ 15% O<sub>2</sub> dry)

CO < 80 mg/Nm<sup>3</sup> (@ 15% O<sub>2</sub> dry)

### In ambient air mode :

NO<sub>x</sub> < 200 mg/Nm<sup>3</sup> (@ 3 % O<sub>2</sub> dry)

CO < 240 mg/Nm<sup>3</sup> (@ 3% O<sub>2</sub> dry)

## COMBUSTION TECHNIQUE APPLIED

Induct burner type REBURNFLAM® LOW NO<sub>x</sub>, section 3700 x 5400 mm




Fig.2 - PILLARD burner type REBURNFLAM® LOW NO<sub>x</sub>

In order to obtain a sufficient combustive velocity through the burner, 3 deflectors have been installed.

The target being to reach a turndown ratio of 1 to 30 in TEG mode, 1 to 50 in ambient air mode, the burner is equipped with 2 natural gas feeds allowing to operate with 2, 4 or 6 rows.

Operational choices :

TEG mode            1,7 to 10 MW : 2 rows  
                           3,4 to 20 MW : 4 rows  
                           5,1 to 30 MW : 6 rows

Ambient air mode 1,7 to 30 MW : 2 rows  
                           3,4 to 60 MW : 4 rows  
                           5,1 to 90 MW : 6 rows

The necessity to obtain less than 200 mg/Nm<sup>3</sup> NO<sub>x</sub> @ 3% O<sub>2</sub> in ambient air mode without CO, meant fitting 4 rows out of 6 with "LOW NO<sub>x</sub>" elements (PILLARD patent n° 00/01455), operated as follows :

Operating with 2 rows            : 2 LOW NO<sub>x</sub> rows  
 Operating with 4 rows            : 2 LOW NO<sub>x</sub> rows (+) 2 standard rows  
 Operating with 6 rows            : 4 LOW NO<sub>x</sub> rows (+) 2 standard rows



## 2 - AUXILIARY BOILERS IN "STAND-BY" MODE

Their purpose is to ensure steam production even if the Cogen unit stops. The 2 auxiliary boilers have been supplied by STANDARD FASEL LENTJES (NL), and are equipped with PILLARD burners, GRC LONOXFLAM gas type.

Main characteristics :

Boilers	:	Production :	50 t/hr	and	80 t/hr steam
		Steam :	40 bar /250°C		
PILLARD burner type :		Heat release	4,8 to 38 MW		7,6 to 61 MW (turndown ratio 1 to 8)
GRC LONOXFLAM gas	:	Number	2		3
		Fuel	natural gas		natural gas




Fig.3 - Position of burners

### TARGETS SET FOR THE AUXILIARY BOILERS

- First, if the cogen unit stops, the boilers must reach their nominal power very quickly (about 30 seconds) so that there is no interruption in steam production.

- Second, to meet the following emissions limits :

$NO_x < 100 \text{ mg/Nm}^3$  (@ 3%  $O_2$  dry)

$CO < 100 \text{ mg/Nm}^3$  (@ 3%  $O_2$  dry)

### COMBUSTION TECHNIQUE APPLIED

The target of  $100 \text{ mg/Nm}^3$   $NO_x$  @ 3%  $O_2$  dry, led to the use of the PILLARD burner, GRC LONOXFLAM gas type which includes an internal FGR principle thanks to a venturi effect, sucking flue gas from the furnace and causing a decrease in the  $O_2$  content of the flame.

In order to maintain the boilers in «stand-by» mode, permanent pilot burners for 5 % of the max heat release have been installed. They allow to maintain the boiler ready to immediately increase its load by lighting up the main burners, increasing their heat release up to 100 % in about 30 seconds.




Fig.4 - PILLARD burner type GRC LONOXFLAM® gas

## MEASURED EMISSIONS

The emissions were verified by CETE APAVE Cy on the 14th of June 2001

For the 80 t/hr boiler :

RESULTATS DE MESURES		Chaud.aux.80 T/H					14-juin-01	
Identification de l'installation et mesures effectuées	Unité	Résultats aux conditions de dilution existantes (basic results)		Résultats aux conditions de référence (Results) (corrected value)			Horaires de prélèvements	
		sur gaz dry	sur gaz humid	formule correctrice	base de correction % H2O CO2 O2			Valeur corrigée
Température du rejet	°C		240		#####	11,79	2,09	
<b>NOx en NO2</b>	mg/Nm <sup>3</sup>	105,32	#DIV/0!	3% O2 sur sec	"	"	"	<b>100,3</b>
NO en NO2	mg/Nm <sup>3</sup>	101,21	#DIV/0!	3% O2 sur sec	"	"	"	<b>96,3</b>
NO2 en NO2	mg/Nm <sup>3</sup>	4,11	#DIV/0!	3% O2 sur sec	"	"	"	<b>3,9</b>
<b>CO</b>	mg/Nm <sup>3</sup>	23,50	#DIV/0!	3% O2 sur sec	"	"	"	<b>22,4</b>

NOx : 100,3 mg/Nm<sup>3</sup> @ 3 % O<sub>2</sub> (dry) (guaranteed 100)  
CO : 22,4 mg/Nm<sup>3</sup> @ 3 % O<sub>2</sub> (dry) (guaranteed 100)

For the 50 t/hr boiler :

RESULTATS DE MESURES		Chaud.aux.50 T/H					14-juin-01	
Identification de l'installation et mesures effectuées	Unité	Résultats aux conditions de dilution existantes (basic results)		Résultats aux conditions de référence (Results) (corrected value)			Horaires de prélèvements	
		sur gaz dry	sur gaz humid	formule correctrice	base de correction % H2O CO2 O2			Valeur corrigée
Température du rejet	°C		240		#####	11,06	2,62	
<b>NOx en NO2</b>	mg/Nm <sup>3</sup>	102,03	#DIV/0!	3% O2 sur sec	"	"	"	<b>99,9</b>
NO en NO2	mg/Nm <sup>3</sup>	97,52	#DIV/0!	3% O2 sur sec	"	"	"	<b>95,5</b>
NO2 en NO2	mg/Nm <sup>3</sup>	4,52	#DIV/0!	3% O2 sur sec	"	"	"	<b>4,4</b>
<b>CO</b>	mg/Nm <sup>3</sup>	<2,50	#DIV/0!	3% O2 sur sec	"	"	"	<b>&lt;2,4</b>

NOx : 99,9 mg/Nm<sup>3</sup> @ 3 % (dry) (guaranteed 100)  
CO : < 2,4 mg/Nm<sup>3</sup> @ 3 % (dry) (guaranteed 100)

In conclusion, all emissions comply with the guaranteed ones.

## CONCLUSION

This plant allowed to reconfirm the performance of :

- REBURNFLAM® LOW NOx postcombustion burners in turndown as well as for low emissions.
- GRC LONOXFLAM gas burners for their flexibility as well as for their low emissions.

In particular it shows the possibility of a very high turndown of 1 to 50 in HRSG's postcombustion burners and the reliable operation of boiler burners allowing to reach the maximum in less than 1 minute in total safety.